



DEPARTMENT OF THE NAVY

NAVAL BASE VENTURA COUNTY

311 MAIN ROAD, SUITE 1

POINT MUGU, CA 93042-5033

5090

Ser N0000CV/0518

July 8, 2019

Child Care Center (CDC) and Youth Center (YC)
Port Hueneme, Point Mugu and Camarillo

Dear Parent or Caregiver:

Subj: NAVAL BASE VENTURA COUNTY CHILD DEVELOPMENT CENTERS
AND YOUTH CENTERS WATER SAMPLING RESULTS

The health and welfare of our Sailors and their families is our top priority. The Navy is committed to maintaining safe drinking water on its installations. Our water distribution system is regularly tested for lead and is in compliance with the Safe Drinking Water Act.

The potential for lead exposure is of particular concern for children. Lead in drinking water may come from plumbing inside buildings to include fittings, solder, water fountains, coolers, and/or water faucets. The Environmental Protection Agency (EPA) therefore recommends, but does not mandate, that we test the lead content of drinking water in priority areas such as Youth Centers (YCs) and Child Development Centers (CDCs). The Navy has adopted these recommendations as policy. Testing at the Point Mugu CDCs and YC was conducted on 29 May 2019. The Port Hueneme and Camarillo's CDC and YC were tested on 5 June 2019.

I am pleased to report that all water intended for consumption, to include drinking water, and water intended for cooking or washing, is below the EPA-recommended lead screening level of 15 parts per billion.

Navy environmental personnel conducted testing at the CDCs and YCs, following Navy and EPA guidelines. All samples were sent to an accredited laboratory for analysis.


Additionally, we tested sinks used for washing. These fixtures were also below recommended screening levels for lead in schools and day care centers. In all, 142 samples were taken and tested.

A copy of all test results is attached. You can also view a copy of our water testing results at the each of the CDCs and YCs, which are open Monday to Friday.

- To learn more about lead in drinking water in schools and day care centers visit the following EPA website: www.cnlic.navy.mil/ventura.
- To learn more about your home's public water supplier, see their annual water quality report:
https://www.cnlic.navy.mil/regions/cnrsw/om/environmental_support/water_quality_information.html

Subj: NAVAL BASE VENTURA COUNTY CHILD DEVELOPMENT CENTERS
AND YOUTH CENTERS WATER SAMPLING RESULTS

While lead in drinking water at these facilities meets EPA recommended screening levels for schools and daycare centers, if you have any health related questions or concerns about lead exposure in general, you are encouraged to contact your health care provider. If you are a TRICARE beneficiary, use the appointment center to schedule an appointment with your primary care provider at 1-866-645-4584.


J. A. CHISM
Captain, U.S. Navy
Commanding Officer

Enclosure: 1. Table 1 – Summary of Water Sampling Results

Table 1. Summary of Results

CATEGORY (water's intended use)	SAMPLE ID	Outlet Description	Comments	INITIAL SAMPLING RESULTS			RE-SAMPLING		CORRECTIVE		
				Lead Screening Level of 15ppb					First Draw (ppb)	Follow up Flush (See Note 1a)	ACTIONS Description
				First Draw (ppb)	Retest required? (YES/NO)	Date Fixture Secured? (See Note 1)	First Draw (ppb)	mm/dd/			
PH-1487 CDC (Lead Screening Level of 15ppb)											
SAMPLING DATE				29-May			12-Jun	mm/dd/			
RESULTS DATE				10-Jun			17-Jun	mm/dd/			
WASHING	H1487-02-PT2-HHWA	Pre Toddler 2 Teacher's Lounge Room 103		1.1	NO	--	--	--	Not Required		
WASHING	H1487-03-PT2-HHWA	Pre Toddler 2 Teacher's Lounge Room 103		2.7	NO	--	--	--	Not Required		
WASHING	H1487-04-PT-LHWA	Pre Toddler Shared Bathroom Rm.103/Rm.104		0.6	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-05-PT-LHWA	Pre Toddler Shared Bathroom Rm.103/Rm.105		0.7	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-06-PT-LHWC	Pre Toddler Shared Bathroom Rm.103/Rm.106		0.6	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-07-PT-LHWD	Pre Toddler Shared Bathroom Rm.103/Rm.107		0.6	NO	--	--	--	Not Required		
WASHING	H1487-08-PT1-HHWA	Pre Toddler 1 Teacher's Lounge Classroom 104		0.5	NO	--	--	--	Not Required		
WASHING	H1487-09-PT1-HHWA	Pre Toddler 1 Teacher's Lounge Classroom 104		0.9	NO	--	--	--	Not Required		
DRINKING	H1487-10-PT1PG-WFB	Pre Toddler 1 Playground (Exterior of Classroom 104)		2.3	NO	--	--	--	Not Required		
WASHING	H1487-11-PS1-HHW	Preschool 1 Teacher's Lounge Room 105		0.7	NO	--	--	--	Not Required		
DRINKING	H1487-12-PS1-WFB	Preschool 1 Classroom Room 105		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-13-PS1-TB	Preschool 1 Classroom Room 105		0.6	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-14-PS1-LHWA	Preschool 1 Bathroom Room 105		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-15-PS1-LHWA	Preschool 1 Bathroom Room 105		0.5	NO	--	--	--	Not Required		
DRINKING	H1487-16-PS1PG-WFB	Preschool Playground (Exterior of Classroom 105)		ND	NO	--	--	--	Not Required		
WATER PLAY	H1487-17-PS1PG-HOSE	Preschool 1 Playground		4.2	NO	--	--	--	Not Required		
WASHING	H1487-18-PS2-HHW	Preschool 2 Teacher's Lounge Room 106		ND	NO	--	--	--	Not Required		
DRINKING	H1487-19-PS2- WFB	Preschool 2 Classroom Room 106		1.7	NO	--	--	--	Not Required		

Table 1. Summary of Results

CATEGORY (water's intended use)	SAMPLE ID	Outlet Description	Comments	INITIAL SAMPLING RESULTS			RE-SAMPLING		CORRECTIVE		
				Lead Screening Level of 15ppb					First Draw (ppb)	Follow up Flush (See Note 1a)	Description
				First Draw (ppb)	Retest required? (YES/NO)	Date Fixture Secured? (See Note 1)	First Draw (ppb)				
WASHING/TEETH BRUSHING	H1487-20-PS2-TB	Preschool 2 Classroom Room 106		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-21-PS2-LHWA	Preschool 2 Bathroom Room 106		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-22-PS2-LHWB	Preschool 2 Bathroom Room 106		0.6	NO	--	--	--	Not Required		
WASHING	H1487-23-PS3-HHW	Preschool 3 Teacher's Lounge Room 107		0.8	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-24-PS3-TB	Preschool 3 Classroom Room 107		ND	NO	--	--	--	Not Required		
DRINKING	H1487-25-PS3-WFB	Preschool 3 Classroom Room 107		2.7	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-26-PS3-LHWA	Preschool 3 Classroom Room 107		0.8	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	H1487-27-PS3-LHWB	Preschool 3 Classroom Room 107		ND	NO	--	--	--	Not Required		
WASHING	H1487-28-K-KA	KITCHEN	Not being used for children.	20	YES	6/11/2019	7.6	NA	Not Required		
COOKING	H1487-29-K-KB	Kitchen		0.7	NO	--	--	--	Not Required		
WASHING	H1487-31-K-DRA	Kitchen		0.8	NO	--	--	--	Not Required		
WASHING	H1487-32-K-DRB	Kitchen		ND	NO	--	--	--	Not Required		
WASHING	H1487-38-I3-HHWA	Infant 3 Teacher's Area Room 108		3.8	NO	--	--	--	Not Required		
DRINKING	H1487-39-I3-HHWA	Infant 3 Teacher's Area Room 108		2.9	NO	--	--	--	Not Required		
DRINKING	H1487-40-I2-HHWA	Infant 3 Teacher's Area Room 109		0.7	NO	--	--	--	Not Required		
WASHING	H1487-41-I2-HHWA	Infant 3 Teacher's Area Room 109		1.6	NO	--	--	--	Not Required		
DRINKING	H1487-42-I1-HHWA	Infant 3 Teacher's Area Room 110		0.8	NO	--	--	--	Not Required		
WASHING	H1487-43-I1-HHWA	Infant 3 Teacher's Area Room 110		2.8	NO	--	--	--	Not Required		
WASHING	H1487-44-SBATH-HHW	Staff Restroom		0.6	NO	--	--	--	Not Required		
DRINKING	H1487-45-HALL-DWC	Hallway Drinking Water Cooler		0.8	NO	--	--	--	Not Required		
WASHING/DRINKING	H1487-46-SRM-HHW	Staff Room		0.8	NO	--	--	--	Not Required		
WASHING	H1487-47-PBATH-HHW	Public Restroom		0.7	NO	--	--	--	Not Required		
WASHING	H1487-48-OFFICE-HHW	Office Support Room		2.1	NO	--	--	--	Not Required		
PH-1391 CDC (Lead Screening Level of 15ppb)											
SAMPLING DATE				29-May			12-Jun	mm/dd/			
RESULTS DATE				10-Jun			17-Jun	mm/dd/			
WASHING	H1391-01-TO-HHWA	Trainer's Office Room 111 Teacher's Lounge	Not being used for children.	18.3	YES	6/11/2019	7.1	NA	Not Required		
WASHING	H1391-02-TO-HHWA	Trainer's Office Room 111 Teacher's Lounge		6.3	NO	--	--	--	Not Required		
WASHING	H1391-03-PT4-HHW	Pre Toddler 4 Teacher's Lounge Room 112		1.7	NO	--	--	--	Not Required		
WASHING	H1391-04-PT-LHWA	Pre Toddler Shared Bathroom Room 112/Room 113		2.8	NO	--	--	--	Not Required		
WASHING	H1391-05-PT-LHWB	Pre Toddler Shared Bathroom Room 112/Room 113		3.1	NO	--	--	--	Not Required		
WASHING	H1391-06-PT-LHWC	Pre Toddler Shared Bathroom Room 112/Room 113		3	NO	--	--	--	Not Required		

Table 1. Summary of Results

CATEGORY (water's intended use)	SAMPLE ID	Outlet Description	Comments	INITIAL SAMPLING RESULTS			RE-SAMPLING		CORRECTIVE	
				Lead Screening Level of 15ppb					Follow up Flush (See Note 1a)	Description
				First Draw (ppb)	Retest required? (YES/NO)	Date Fixture Secured? (See Note 1)	First Draw (ppb)			
WASHING	H1391-07-PTPG-WFB	Pre Toddler 4 Playground (Exterior Of Room 112)		11.6	NO	--	--	--	Not Required	
WASHING	H1391-08-PT3-HHW	Pre Toddler Teacher's Lounge Room 113		2.1	NO	--	--	--	Not Required	
WASHING	H1391-09-HALL-WFC	Multi-Purpose Room		ND	NO	--	--	--	Not Required	
WASHING	H1391-10-K-DR	Kitchen		0.9	NO	--	--	--	Not Required	
COOKING	H1391-12-K-K	Kitchen		2.9	NO	--	--	--	Not Required	
WASHING	H1391-13-K-HHW	Kitchen		4.8	NO	--	--	--	Not Required	
WASHING	H1391-17-T1-HHW	Toddler 1 Teacher's Lounge Room 114		4.6	NO	--	--	--	Not Required	
WASHING/TEETH BRUSHING	H1391-18-T1&2-LHWA	Toddler Shared Bathroom Room 114/Room 115		1.9	NO	--	--	--	Not Required	
WASHING/TEETH BRUSHING	H1391-19-T1&2-LHWB	Toddler Shared Bathroom Room 114/Room 115		2.1	NO	--	--	--	Not Required	
WASHING/TEETH BRUSHING	H1391-20- T1&2-LHWC	Toddler Shared Bathroom Room 114/Room 115		3.9	NO	--	--	--	Not Required	
WASHING/TEETH BRUSHING	H1391-21- T1&2-LHWD	Toddler Shared Bathroom Room 114/Room 115		2.6	NO	--	--	--	Not Required	
WASHING	H1391-22-T2-HHW	Toddler 2 Teacher's Lounge Room 115		4.3	NO	--	--	--	Not Required	
WASHING	H1391-24-T3-HHWB	Toddler 3 Teacher's Lounge Room 116		4.7	NO	--	--	--	Not Required	
WASHING/TEETH BRUSHING	H1391-25-T3-LHWA	Toddler 3 Bathroom Room 116		2.1	NO	--	--	--	Not Required	
WASHING/TEETH BRUSHING	H1391-26-T3-LHWB	Toddler 3 Bathroom Room 116		2.4	NO	--	--	--	Not Required	
WASHING/TEETH BRUSHING	H1391-27-T3-LHWC	Toddler 3 Bathroom Room 116		1.8	NO	--	--	--	Not Required	
WASHING	H1391-28-T3PG-WFB	Toddler 3 Playground (Exterior of Room 116)		9.5	NO	--	--	--	Not Required	
WASHING	H1391-30-SRM-HHW	Staff Room		4	NO	--	--	--	Not Required	
WASHING	H1391-31-SBATH-HHW	Staff Restroom		1.3	NO	--	--	--	Not Required	
WASHING	H1391-32-TBATH-HHW	Teacher's Work Area Restroom		5.7	NO	--	--	--	Not Required	
WASHING	H1391-33-PBATH-HHW	Lobby Restroom		6.3	NO	--	--	--	Not Required	
WATER PLAY	H1391-34-T3PG-HOSE	Playground east of office		0.6	NO	--	--	--	Not Required	

Table 1. Summary of Results

CATEGORY (water's intended use)	SAMPLE ID	Outlet Description	Comments	INITIAL SAMPLING RESULTS			RE-SAMPLING		CORRECTIVE		
				Lead Screening Level of 15ppb					First Draw (ppb)	Follow up Flush (See Note 1a)	ACTIONS Description
				First Draw (ppb)	Retest required? (YES/NO)	Date Fixture Secured? (See Note 1)	mm/dd/yyyy	mm/dd/yyyy			
PH-1439 YC (Lead Screening Level of 15ppb)											
SAMPLING DATE				29-May			mm/dd/yyyy	mm/dd/			
RESULTS DATE				10-Jun			mm/dd/yyyy	mm/dd/			
WATER PLAY	H1439-01-WESTPG-HOSE	West of Multi-Purpose Room		4.7	NO	--	--	--	Not Required		
WASHING	H1439-02-K-K	Kitchen		ND	NO	--	--	--	Not Required		
DRINKING	H1439-04-HALL-WFC	Hallway by Girl's Bathroom		ND	NO	--	--	--	Not Required		
WASHING	H1439-05-GBATH-HHW	Girl's Bathroom		1.4	NO	--	--	--	Not Required		
WASHING	H1439-06-GBATH-LHWA	Girl's Bathroom		2.1	NO	--	--	--	Not Required		
WASHING	H1439-07-GBATH-LHWB	Girl's Bathroom		2.1	NO	--	--	--	Not Required		
WASHING	H1439-08-GBATH-LHWC	Girl's Bathroom		2	NO	--	--	--	Not Required		
WASHING	H1439-09-BBATH-LHWA	Boy's Bathroom		1.2	NO	--	--	--	Not Required		
WASHING	H1439-10-BBATH-LHWB	Boy's Bathroom		2	NO	--	--	--	Not Required		
WASHING	H1439-11-BBATH-HHW	Boy's Bathroom		1.4	NO	--	--	--	Not Required		
WASHING	H1439-12-SBATH-HHWA	Staff Bathroom		3.2	NO	--	--	--	Not Required		
WASHING	H1439-13-SBATH-HHWB	Staff Bathroom		0.5	NO	--	--	--	Not Required		
WATER PLAY	H1439-14-EASTPG-HOSE	East of Staff Restroom (Exterior)		8.1	NO	--	--	--	Not Required		
PM-173 CDC (Lead Screening Level of 15ppb)											
SAMPLING DATE				5-Jun			mm/dd/yyyy	mm/dd/			
RESULTS DATE				12-Jun			mm/dd/yyyy	mm/dd/			
WASHING	M173-01-SRM-HHW	Staff Room		ND	NO	--	--	--	Not Required		
WASHING	M173-02-PBATH-HHW	Public/Staff Restroom		0.9	NO	--	--	--	Not Required		
COOKING	M173-07-K-K	Kitchen		0.7	NO	--	--	--	Not Required		
WASHING	M173-08-K-DR1	Kitchen		1	NO	--	--	--	Not Required		
WASHING	M173-09-K-DR2	Kitchen		0.9	NO	--	--	--	Not Required		
WASHING	M173-10-K-DR3	Kitchen		6.3	NO	--	--	--	Not Required		
WASHING	M173-11-K-HHW	Kitchen		1.8	NO	--	--	--	Not Required		
EXTERIOR	M173-12-K-HOSE	Kitchen (Exterior)		1.1	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-13-PS2-TB	Preschool 2 Classroom 109		ND	NO	--	--	--	Not Required		
DRINKING	M173-14-PS2-WFB	Preschool 2 Classroom 109		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-15-PS2-LHWA	Preschool 2 Bathroom 109		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-16-PS2-LHWB	Preschool 2 Bathroom 109		ND	NO	--	--	--	Not Required		
WASHING	M173-17-PS2-HHW	Preschool 2 Classroom 109 Teacher's Lounge		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-18-PS1-TB	Preschool 1 Classroom 111		ND	NO	--	--	--	Not Required		
DRINKING	M173-19-PS1-WFB	Preschool 1 Classroom 111		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-20-PS1-LHWA	Preschool 1 Bathroom 111		1.2	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-21-PS1-LHWB	Preschool 1 Bathroom 111		ND	NO	--	--	--	Not Required		
WASHING	M173-22-PS1-HHW	Preschool 1 Classroom 111 Teacher's Lounge		ND	NO	--	--	--	Not Required		

Table 1. Summary of Results

CATEGORY (water's intended use)	SAMPLE ID	Outlet Description	Comments	INITIAL SAMPLING RESULTS			RE-SAMPLING		CORRECTIVE		
				Lead Screening Level of 15ppb					First Draw (ppb)	Follow up Flush (See Note 1a)	ACTIONS Description
				First Draw (ppb)	Retest required? (YES/NO)	Date Fixture Secured? (See Note 1)	First Draw (ppb)				
WASHING/TEETH BRUSHING	M173-23-T-TB	Toddler Classroom 113		ND	NO	--	--	--	Not Required		
DRINKING	M173-24-T-WFB	Toddler Classroom 113		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-25-T-LHWA	Toddler Bathroom 113		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-26-T-LHWB	Toddler Bathroom 113		ND	NO	--	--	--	Not Required		
WASHING	M173-27-T-HHW	Toddler Classroom 113 Teacher's Lounge		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-29-PT-TB	Pre-Toddler Classroom 118		ND	NO	--	--	--	Not Required		
DRINKING	M173-30-PT-WFB	Pre-Toddler Classroom 118		0.6	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-31-PT-LHWA	Pre-Toddler Bathroom 118		ND	NO	--	--	--	Not Required		
WASHING/TEETH BRUSHING	M173-32-PT-LHWB	Pre-Toddler Bathroom 118		0.7	NO	--	--	--	Not Required		
WASHING	M173-33-PT-HHW	Pre-Toddler Classroom 118 Teacher's Lounge		1.5	NO	--	--	--	Not Required		
WASHING	M173-34-I-LHW	Infant Classroom 121		ND	NO	--	--	--	Not Required		
DRINKING	M173-35-I-WFB	Infant Classroom 121		4.9	NO	--	--	--	Not Required		
WASHING	M173-36-I-LHWA	Infant Bathroom 121	not being used by infant.	3.7	NO	--	--	--	Not Required		
WASHING	M173-37-I-LHWB	Infant Bathroom 121	not being used by infant.	2.6	NO	--	--	--	Not Required		
WASHING	M173-38-I-HHW	Infant Classroom 121 Teacher's Lounge		0.6	NO	--	--	--	Not Required		
PM-150 YC (Lead Screening Level of 15ppb)											
SAMPLING DATE				5-Jun			mm/dd/yyyy	mm/dd/			
RESULTS DATE				12-Jun			mm/dd/yyyy	mm/dd/			
DRINKING	M150-01-PG-WFC	Outdoor Table Area/ Playground		ND	NO	--	--	--	Not Required		
WASHING	M150-04-RM1-HHW	Classroom 1 CDH Office		0.7	NO	--	--	--	Not Required		
WASHING	M150-05-RM2-HHW	Classroom 2		0.9	NO	--	--	--	Not Required		
WASHING	M150-07-SRM-HHW	Staff Room		1.2	NO	--	--	--	Not Required		
WASHING	M150-08-FSA-K	Food Storage Area		1.6	NO	--	--	--	Not Required		
WASHING	M150-09-GBATH-HHWA	Girl's Bathroom		ND	NO	--	--	--	Not Required		
WASHING	M150-10-GBATH-HHWB	Girl's Bathroom		ND	NO	--	--	--	Not Required		
WASHING	M150-11-GBATH-HHWC	Girl's Bathroom		ND	NO	--	--	--	Not Required		
WASHING	M150-12-PBATH-HHW	Unisex Public Restroom		ND	NO	--	--	--	Not Required		
DRINKING	M150-13-HALL-WFC	Interior Hallway		ND	NO	--	--	--	Not Required		
WASHING	M150-14-BBATH-HHWA	Boy's Bathroom		ND	NO	--	--	--	Not Required		
WASHING	M150-15-BBATH-HHWB	Boy's Bathroom		0.8	NO	--	--	--	Not Required		
WASHING	M150-16-BBATH-HHWC	Boy's Bathroom		ND	NO	--	--	--	Not Required		

Table 1. Summary of Results

CATEGORY (water's intended use)	SAMPLE ID	Outlet Description	Comments	INITIAL SAMPLING RESULTS			RE-SAMPLING		CORRECTIVE		
				Lead Screening Level of 15ppb					First Draw (ppb)	Follow up Flush (See Note 1a)	ACTIONS Description
				First Draw (ppb)	Retest required? (YES/NO)	Date Fixture Secured? (See Note 1)	mm/dd/yyyy	mm/dd/			
CAM-124 YC (Lead Screening Level of 15ppb)											
SAMPLING DATE				5-Jun			mm/dd/yyyy	mm/dd/			
RESULTS DATE				12-Jun			mm/dd/yyyy	mm/dd/			
WASHING	C1124-02-SBATH-HHW	Staff Restroom		1.6	NO	--	--	--	Not Required		
WATER PLAY	C1124-03-PG-HOSE	Outdoor Playground		5	NO	--	--	--	Not Required		
COOKING	C1124-04-K-HHW	Kitchen		0.6	NO	--	--	--	Not Required		
WASHING	C1124-06-SRM-HHW	Staff Lounge, Room 108		1.6	NO	--	--	--	Not Required		
DRINKING	C1124-07-HALL-WFCA	Hallway outside Staff Lounge and Central Storage		0.5	NO	--	--	--	Not Required		
DRINKING	C1124-08-HALL-WFCB	Hallway outside Staff Lounge and Central Storage		0.8	NO	--	--	--	Not Required		
WASHING	C1124-09-RM118-HHW	Multipurpose room Room 118		0.6	NO	--	--	--	Not Required		
WASHING	C1124-10-RM117-HHW	Multipurpose room Room 117		0.7	NO	--	--	--	Not Required		
WASHING	C1124-11-RM115-HHW	Multipurpose room Room 115		1.1	NO	--	--	--	Not Required		
WASHING	C1124-12-BBATH-HHWA	Boy's Bathroom		1.4	NO	--	--	--	Not Required		
WASHING	C1124-13-BBATH-HHWA	Boy's Bathroom		1.2	NO	--	--	--	Not Required		
WASHING	C1124-14-GBATH-HHWA	Girl's Bathroom		ND	NO	--	--	--	Not Required		
WASHING	C1124-15-GBATH-HHWA	Girl's Bathroom		1.8	NO	--	--	--	Not Required		
WASHING	C1124-16-GBATH-HHWC	Girl's Bathroom		0.7	NO	--	--	--	Not Required		

Notes:

1 - Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 15ppb.

1a - Follow up Flush - Collected 30 seconds after First Draw Sampling. No flush samples were required because all of the first draw samples were below the action level.