

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
Patrick Wade									
PWCDC-HB2	0.16	WATER PLAY	H540-01	8/24/2019	NO				
PWCDC-HB3	12.5	WATER PLAY	H540-02	8/24/2019	NO				
PWCDC-BB3	0.147	DRINKING	H540-03	8/24/2019	NO				
PWCDC_KITCHEN_S2B	0.705	COOKING	H540-04	8/24/2019	NO				
PWCDC_KITCHEN_S6	0.214	COOKING	H540-05	8/24/2019	NO				
R137_TODDLR_S5	0.393	DRINKING	19H539-01	8/24/2019	NO				
R139_TODDLR_S1	0.438	DRINKING	19H539-02	8/24/2019	NO				
R139_TODDLR_S2	0.461	DRINKING	19H539-03	8/24/2019	NO				
R139_TODDLR_S3	0.356	DRINKING	19H539-04	8/24/2019	NO				
R139_TODDLR_S4	0.472	DRINKING	19H539-05	8/24/2019	NO				
R139_TODDLR_S5	0.749	DRINKING	19H539-06	8/24/2019	NO				
R141_TODDLR_S1	0.534	DRINKING	19H539-07	8/24/2019	NO				
R141_TODDLR_S2	0.694	DRINKING	19H539-08	8/24/2019	NO				
R141_TODDLR_S3	0.835	DRINKING	19H539-09	8/24/2019	NO				
R141_TODDLR_S4	0.302	DRINKING	19H539-10	8/24/2019	NO				
R141_TODDLR_S5	0.673	DRINKING	19H539-11	8/24/2019	NO				
R143_TODDLR_S1	0.451	DRINKING	19H539-12	8/24/2019	NO				
R143_TODDLR_S2	0.923	DRINKING	19H539-13	8/24/2019	NO				
R143_TODDLR_S3	0.556	DRINKING	19H539-14	8/24/2019	NO				
R143_TODDLR_S4	0.523	DRINKING	19H539-15	8/24/2019	NO				
R143_TODDLR_S5	0.604	DRINKING	19H539-16	8/24/2019	NO				
TDLRHALL_RR_S1	0.795	DRINKING	19H539-17	8/24/2019	NO				
PWCDC-BB1*	1780	DRINKING	H539-18G	8/24/2019	YES*				RE-SAMPLE/RE-TEST
PWCDC-BB1*2FD	0.1	DRINKING	I501-01	9/12/2019	YES*	0.1		9/12/2019	NO ACTION
PWCDC-BB1*30SF	0.1	DRINKING	I501-02	9/12/2019	YES*		0.1	9/12/2019	NO ACTION
PWCDC_HB1*	0.175	WATER PLAY	19H539-19	8/24/2019	NO*				
PWCDC-HB1*2FD	0.893	WATER PLAY	I501-03	9/12/2019	NO*	0.893		9/12/2019	NO ACTION
PWCDC-HB1*30SF	0.144	WATER PLAY	I501-04	9/12/2019	NO*		0.144	9/12/2019	NO ACTION
PWCDC_BB2	2.91	DRINKING	19H539-20	8/24/2019	NO				

* Sampling technician mislabeled PWCDC-BB1 as PWCDC-HB1 during initial testing. During re-sampling both locations were sampled to ensure data integrity.

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
Patrick Wade									
R134_PRETOD_S3	0.645	DRINKING	H538-01	8/24/2019	NO				
R150_INFANT_S1	0.331	DRINKING	H538-02	8/24/2019	NO				
R150_INFANT_S2	0.584	DRINKING	H538-03	8/24/2019	NO				
R150_INFANT_S3	1.62	DRINKING	H538-04	8/24/2019	NO				
R152_INFANT_S1	0.594	DRINKING	H538-05	8/24/2019	NO				
R152_INFANT_S2	0.593	DRINKING	H538-06	8/24/2019	NO				
R152_INFANT_S3	0.732	DRINKING	H538-07	8/24/2019	NO				
R154_INFANT_S1	0.654	DRINKING	H538-08	8/24/2019	NO				
R154_INFANT_S2	0.609	DRINKING	H538-09	8/24/2019	NO				
R154_INFANT_S3	2.1	DRINKING	H538-10	8/24/2019	NO				
R156_INFANT_S1	0.372	DRINKING	H538-11	8/24/2019	NO				
R156_INFANT_S2	1.72	DRINKING	H538-12	8/24/2019	NO				
R156_INFANT_S3	0.619	DRINKING	H538-13	8/24/2019	NO				
R158_INFANT_S1	0.293	DRINKING	H538-14	8/24/2019	NO				
R158_INFANT_S2	0.802	DRINKING	H538-15	8/24/2019	NO				
R158_INFANT_S3	0.634	DRINKING	H538-16	8/24/2019	NO				
R137_TODDLR_S1	0.536	DRINKING	H538-17	8/24/2019	NO				
R137_TODDLR_S2	0.749	DRINKING	H538-18	8/24/2019	NO				
R137_TODDLR_S3	0.28	DRINKING	H538-19	8/24/2019	NO				
R137_TODDLR_S4	0.573	DRINKING	H538-20	8/24/2019	NO				
R103-PRESCI_S1	0.406	DRINKING	H537-01	8/24/2019	NO				
R103-PRESCI_S2	1.14	DRINKING	H537-02	8/24/2019	NO				
R103-PRESCI_S3	0.556	DRINKING	H537-03	8/24/2019	NO				
R103-PRESCI_S4	0.555	DRINKING	H537-04	8/24/2019	NO				
R103-PRESCI_S5	0.735	DRINKING	H537-05	8/24/2019	NO				
PWCDC_W1	0.14	DRINKING	H537-06	8/24/2019	NO				
R126_PRETOD_S1	1.16	DRINKING	H537-07	8/24/2019	NO				
R126_PRETOD_S2	0.647	DRINKING	H537-08	8/24/2019	NO				
R126_PRETOD_S3	0.757	DRINKING	H537-09	8/24/2019	NO				
R128_PRETOD_S1	0.466	DRINKING	H537-10	8/24/2019	NO				

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
Patrick Wade									
R128_PRETOD_S2	0.476	DRINKING	H537-11	8/24/2019	NO				
R128_PRETOD_S3	0.53	DRINKING	H537-12	8/24/2019	NO				
R130_PRETOD_S1	0.65	DRINKING	H537-13	8/24/2019	NO				
R130_PRETOD_S2	0.986	DRINKING	H537-14	8/24/2019	NO				
R130_PRETOD_S3	0.625	DRINKING	H537-15	8/24/2019	NO				
R132_PRETOD_S1	0.72	DRINKING	H537-16	8/24/2019	NO				
R132_PRETOD_S2	0.866	DRINKING	H537-17	8/24/2019	NO				
R132_PRETOD_S3	0.899	DRINKING	H537-18	8/24/2019	NO				
R134_PRETOD_S1	0.615	DRINKING	H537-19	8/24/2019	NO				
R134_PRETOD_S2	0.966	DRINKING	H537-20	8/24/2019	NO				
WrkR-RR_S1	0.781	washing	H536-01	8/24/2019	NO				
Off-RR_S1	0.784	washing	H536-02	8/24/2019	NO				
Brk-Rm_S1	0.416	DRINKING	H536-03	8/24/2019	NO				
Janitorial_S1	1.45	washing	H536-04	8/24/2019	NO				
Laundry_S1	1.73	washing	H536-05	8/24/2019	NO				
Kitchen_S1	0.19	COOKING	H536-06	8/24/2019	NO				
Ktchn_S2A	0.856	COOKING	H536-07	8/24/2019	NO				
Ktchn_S3	1.93	COOKING	H536-08	8/24/2019	NO				
Ktchn_S4	0.474	COOKING	H536-09	8/24/2019	NO				
Ktchn_S5	0.353	COOKING	H536-10	8/24/2019	NO				
R107-PS_S1	0.534	DRINKING	H536-11	8/24/2019	NO				
R107-PS_S2	0.714	DRINKING	H536-12	8/24/2019	NO				
R107-PS_S3	0.298	DRINKING	H536-13	8/24/2019	NO				
R107-PS_S4	1.35	DRINKING	H536-14	8/24/2019	NO				
R107-PS_S5	1.13	DRINKING	H536-15	8/24/2019	NO				
R106-PS_S1	0.346	DRINKING	H536-16	8/24/2019	NO				
R106-PS_S2	0.34	DRINKING	H536-17	8/24/2019	NO				
R106-PS_S3	0.546	DRINKING	H536-18	8/24/2019	NO				
R106-PS_S4	0.442	DRINKING	H536-19	8/24/2019	NO				
R106-PS_S5	0.802	DRINKING	H536-20	8/24/2019	NO				