

SAMPLE ID NAME	Sampling Results greater than 15 parts per billion (ppb) require re-sampling					Re- sampling Results			Corrective Actions Description
	First draw Results (ppb)	Water Intended use	Lab Sample Control #	Sample Collection Date	Retest required (yes) / (no)	Lead screening Level 15 ppb		Re-Sample Collection Date	
						First draw (ppb)	Follow-up flush (ppb)		
Serra									
T.T.RM-S1	0.2555	DRINKING	19H53501	8/21/2019	NO				
SAC-RM-S1	0.305	DRINKING	19H53502	8/21/2019	NO				
KITCHEN-S1	0.369	COOKING	19H53503	8/21/2019	NO				
G-RR-S1	0.298	WASHING	19H53504	8/21/2019	NO				
G-RR-S2	0.371	WASHING	19H53505	8/21/2019	NO				
B-RR-S1	0.739	WASHING	19H53506	8/21/2019	NO				
B-RR-S2	0.331	WASHING	19H53507	8/21/2019	NO				
TEEN.RM-S1	0.326	DRINKING	19H53508	8/21/2019	NO				
BB1	0.242	DRINKING	19H53509	8/21/2019	NO				
BB2	0.226	DRINKING	19H53510	8/21/2019	NO				
HB1	0.903	WATER PLAY	19H53511	8/21/2019	NO				
HB2	3.25	WATER PLAY	19H53512	8/21/2019	NO				